



# PIPEWORK

Minimum clearance of 300mm from opening/internal wall in accordance with B.S. 5440, Part J of the building regulations requirements

Water supply boiler located

1/2" MNV2 rated blending valve to be fitted at bath connection. Must comply with local authority requirements.

NOTE :- AIR VENTS TO BE INSTALLED AT HIGH POINTS AND PIPEWORK TO CORRECTLY GRADED

